

Table 1. Groundwater Analytical Results, Delegarde Supply Well, Tutu Wells Site, U.S. Virgin Islands

Parameter Detected	Date Sampled		Federal Drinking Water Standard
	May 26, 1994	July 27, 1994	
1, 2-dichloroethene (total)	6.0	8.5	170
Trichloroethene	4.2	4.3	5
Tetrachloroethene	14	16	5
Chloroform	ND	0.16J	NS
tert-Butyl Methyl ether	NA	7.0J	NS

All concentrations in parts per billion

ND Not detected
NA Not analyzed
J Estimated result below laboratory detection limit
NS Not specified

